

学校名	対象建物	方向	階	今回診断結果 Is
城北養護	校舎①	X	PH	1.45
			2	0.69
			1	0.64
		Y	PH	0.61
			2	1.47
			1	0.90
	校舎②	X	PH	0.53
			2	0.61
			1	0.60
		Y	PH	1.23
			2	1.55
			1	1.22
	校舎③	X	PH	1.20
			2	0.40
			1	0.40
		Y	PH	0.55
			2	1.32
			1	0.81
	寄宿舎④	X	3	
			2	
			1	0.69
		Y	3	
			2	
			1	1.82
	寄宿舎⑤	X	3	
			2	
			1	0.69
Y		3		
		2		
		1	1.40	
屋内体育館⑥	X	3		
		2	0.50	
		1	0.56	
	Y	3		
		2	1.83	
		1	1.10	